

SPECIFICATION SOLUTIONS

ELECTRO™
POWDERCOAT RANGE



Reaction to fire
test results



Worth doing, worth Dulux.®

Worth doing. Worth Dulux.®


ELECTRO™

POWDERCOAT RANGE

Two industry standard 'reaction-to-fire' tests have been carried out for the Dulux Electro Premium Powder coat range in accordance with the Australian and New Zealand building codes to determine the Group Number Classification and Ignitability, Spread of Flame, Heat Evolved and Smoke Developed Indices.

The project: RMIT Student Accommodation.
Bundoora, Australia

Photo credit: Diana Snape



Test results

Industry Standard: AS/NZS1530.3-1999

Methods for fire tests on building materials, components and structures Part 3:
Simultaneous determination of ignitability, flame propagation, heat release and smoke release

Standard	This Standard sets out a test method for the assessment of building materials and components to measure their behaviour and contribution to the progress of fire and further spread of it. These include:				(a) their tendency to ignite; (b) their tendency to propagate flame; (c) the heat they release once ignition has occurred; and (d) their tendency to release smoke.
Purpose	Dulux Powder Coatings has undertaken independent testing in accordance with AS/NZS 1530.3 – 1999 to allow consumers and/or regulatory bodies to determine the suitability of its architectural grade coating systems for aluminium coated extrusions, sheets, claddings, fixings, components, etc with regards to the fire hazard of the coating. The test results outlined below are specific to Dulux Electro super durable polyester architectural grade powder coat finishes.				
Regulatory Indices	Index	Ignitability Index	Spread of Flame Index	Heat Evolved Index	Smoke Developed Index
	Range	(0-20)	(0-10)	(0-10)	(0-10)
	Score	0	0	0	3
Results Analysis	According to NCC (National Construction Code) volume one specification C1.9 e (v) of the Building Code of Australia (BCA) 2019, Electro may be used wherever a non-combustible material is required on pre-finished or powder coated metal sheeting having a combustible surface finish not exceeding 1 mm thickness and where the Spread-of-Flame Index of the product is not greater than 0. The specimen was tested on a Group 4 (least reactive) substrate as specified by Clause 4.4.3 of AS1530.3:1999. These results only apply to any substrate in the same group or a less reactive material. The results of this fire test may be used to directly assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all fire conditions.				

Industry Standard: AS 5637.1:2015

Determination of Fire Hazard Properties – Wall & Ceiling linings

Standard	<p>The standard sets out procedures for the assessment of wall & ceiling linings to provide means for the determination of a Group Number Classification according to:</p> <p>(a) their tendency to ignite; (b) their tendency to release heat once ignition has occurred; (c) their tendency to cause flashover; (d) their tendency to release smoke; and (e) their contribution to fire growth.</p>							
Purpose	<p>Dulux Powder Coatings has undertaken independent testing to determine the Group Number Classification</p> <p>Group Number Classification in accordance with the New Zealand Building Code Calculations were carried out according to NZBC Verification Method C/VM2 Appendix A. The classification for the sample is given in the table below.</p> <p>Group Number Classification in accordance with NCC Australia Calculations were carried out according to AS5637.1:2015. The Group Number Classification and Average Smoke Extinction Area for the sample is given in the table below.</p> <p>Determination of Fire Hazard Properties The specimen was deemed suitable for testing in accordance with AS 5637.1:2015 and testing was performed in accordance with ISO 5660 for the purposes of Group Number Classification as specified in the NCC volume one specification C1.10 C (viii) of the Building Code of Australia (BCA) 2019 for the classification of wall and ceiling linings.</p>							
Results Analysis	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="background-color: #808080; color: white;">Building Code Document</th> <th style="background-color: #808080; color: white;">Group Number Classification</th> </tr> </thead> <tbody> <tr> <td>NZBC Verification Method C/VM2 Appendix A: Establishing Group Numbers for lining materials</td> <td style="text-align: center;">1-S</td> </tr> <tr> <td>NCC Volume One Specification C1.10 C (viii) determined in accordance with AS 5637.1:2015</td> <td style="text-align: center;">1 The average specific extinction area was less than the 250 m²/kg limit</td> </tr> </tbody> </table> <p>Group 1 is the highest (best) classification and Group 4 is the poorest performing classification.</p> <p>The tests conducted according to the BCA assess the contribution that surface finishes make to the spread of fire and smoke to ensure that the building is protected from the spread of fire and smoke to allow sufficient time for the orderly evacuation of the building in an emergency.</p>		Building Code Document	Group Number Classification	NZBC Verification Method C/VM2 Appendix A: Establishing Group Numbers for lining materials	1-S	NCC Volume One Specification C1.10 C (viii) determined in accordance with AS 5637.1:2015	1 The average specific extinction area was less than the 250 m ² /kg limit
Building Code Document	Group Number Classification							
NZBC Verification Method C/VM2 Appendix A: Establishing Group Numbers for lining materials	1-S							
NCC Volume One Specification C1.10 C (viii) determined in accordance with AS 5637.1:2015	1 The average specific extinction area was less than the 250 m ² /kg limit							

Further information

Detailed reports

For a copy of the detailed independent test results for Dulux Electro Architectural Powder Coat range referring to in this document please contact your Dulux representative or call our Advice Line referring to the reports below.

	AS/NZS1530.3-1999	AS 5637.1:2015
Report Reference	CSIRO Product testing – Report No. FNE 11837 (December 2016)	BRANZ – Report No. FH 5532-TT ISSUE 2 (2018)

Standards

For copies of the standards referenced in this document please refer to:.

	AS/NZS1530.3-1999	AS 5637.1:2015
Standards Reference	To access AS/NZS1530.3-1999 visit Australian or New Zealand Standards websites	To access AS 5637.1:2015 visit Australian or New Zealand Standards websites

Other Dulux reaction to fire test results

For other Dulux Architectural Powder coat range test reports for Reaction to Fire visit

Australia: duluxpowders.com.au/specifications or call 13 24 99

New Zealand: duluxpowders.co.nz/specifications or call 0800 800 975

Advice line

Our dedicated consultants can help simplify the specification process, saving you time and money by providing the right coating advice for your project.

Australia

Call 13 24 99 or visit
duluxpowders.com.au

New Zealand

Call 0800 800 975 or visit
duluxpowders.co.nz

Offices

Australia

Dulux Powder & Industrial Coatings
1-15 Pound Road West
Dandenong South VIC 3175
T (61) 3 8787 4500

New Zealand

Dulux Powder & Industrial Coatings
31B Hillside Road
Glenfield, Auckland, New Zealand
T (64) 9 441 8244

Singapore

DGL International Powder & Industrial Coatings
No. 100 Pasir Panjang Road
#02-10, Singapore 118518
T (65) 6 8381 020

China

DGL International Powder & Industrial Coatings
Room 406, No.8, Lane 1977, JinShaJiang Road,
Shanghai, China, PC 200333
T (86) 21 6173 8800

Dulux, Duralloy, Precious, Duratec, Electro, Fluoraset, Zincshield, Worth doing, worth Dulux and Dulux World of Colour are registered trade marks and Alumi Shield, Steel Shield, E-Prime and Dulux Accredited Powder Coater are trade marks of DuluxGroup (Australia) Pty Ltd. Copyright 2020 DuluxGroup (Australia) Pty Ltd.



Worth doing, worth Dulux.®